


# WHITE RIVER TOWNSHIP FIRE DEPARTMENT FIRE HYDRANT FIRE LANE MARKING DETAIL



FIRE LANE TO BE 12 ' IN DEPTH FROM EDGE OF PAVEMENT OR CURB.  
 LETTERS TO BE 3' IN HEIGHT & MINIMUM OF 4" WIDE.  
 STRIPPING TO BE MINIMUM OF 4" WIDE @ 45 DEGREE ANGLE & 5' ON CENTER.  
 ALL MARKINGS TO BE TRAFFIC WHITE.  
 SIGNAGE TO READ "NO PARKING FIRE LANE TOW AWAY ZONE."  
 SIGNAGE TO MEET UNIFORM TRAFFIC CONTROL DEVICES MANUAL.  
 10-08-02