


WHITE RIVER TOWNSHIP FIRE DEPARTMENT FIRE HYDRANT VEHICLE PROTECTION AND FIRE LANE MARKING DETAIL



FIRE LANE TO BE 12 ' IN DEPTH FROM EDGE OF PAVEMENT OR CURB.
 LETTERS TO BE 3' IN HEIGHT & MINIMUM OF 4" WIDE.
 STRIPPING TO BE MINIMUM OF 4" WIDE @ 45 DEGREE ANGLE & 5' ON CENTER.
 ALL MARKINGS TO BE TRAFFIC WHITE.
 SIGNAGE TO READ "NO PARKING FIRE LANE TOW AWAY ZONE."
 SIGNAGE TO MEET UNIFORM TRAFFIC CONTROL DEVICES MANUAL